

Pace Analytical Services, LLC

1700 Elm Street - Suite 200

Minneapolis, MN 55414

(612)607-1700



ANALYTICAL RESULTS

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

Sample: Room2-54/ Girls Bath/RightSink		Lab ID: 10366511019	Collected: 10/08/16 00:34	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	67.7	ug/L	0.10	1		10/22/16 13:24	7439-92-1	
Sample: Room2-55/Boys Bath		Lab ID: 10366511020	Collected: 10/08/16 00:34	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	3.4	ug/L	0.10	1		10/22/16 13:26	7439-92-1	
Sample: Room2-57/Classroom/Left Sink		Lab ID: 10366511021	Collected: 10/08/16 00:30	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	1.6	ug/L	0.10	1		10/20/16 13:25	7439-92-1	
Sample: Room2-57/Classroom/Right Sink		Lab ID: 10366511022	Collected: 10/08/16 00:30	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	2.1	ug/L	0.10	1		10/20/16 13:29	7439-92-1	
Sample: Room2-58/		Lab ID: 10366511023						
Parameters	Results	Units						

ANALYTICAL RESULTS

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

Sample: Room2-62/Dept. Head Office		Lab ID: 10366511025	Collected: 10/08/16 00:40	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	378	ug/L	0.10	1		10/20/16 13:33	7439-92-1	
Sample: Room2-63/Classroom		Lab ID: 10366511026	Collected: 10/08/16 00:41	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	157	ug/L	0.10	1		10/20/16 13:37	7439-92-1	
Sample: Room2-66/Classroom		Lab ID: 10366511027	Collected: 10/08/16 00:43	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	25.5	ug/L	0.10	1		10/20/16 13:38	7439-92-1	
Sample: Room2-67/Classroom		Lab ID: 10366511028	Collected: 10/08/16 00:45	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	12.1	ug/L	0.10	1		10/20/16 13:39	7439-92-1	
Sample: Room2-68/Classroom		Lab ID: 10366511029	Collected: 10/08/16 00:46	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	13.9	ug/L	0.10	1		10/20/16 13:40	7439-92-1	
Sample: Room2-70/Hallway Fount./Upper		Lab ID: 10366511030	Collected: 10/08/16 00:55	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	6.1	ug/L	0.10	1		10/20/16 13:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

Sample: Room2-70/Hallway Fount./Lower		Lab ID: 10366511031	Collected: 10/08/16 00:55	Received: 10/14/16 09:45	Matrix: Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS, DW		Analytical Method: EPA 200.8						
Lead	11.1	ug/L	0.10	1		10/20/16 13:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

QC Batch: 442005 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10366511001, 10366511002, 10366511003, 10366511004, 10366511005, 10366511006, 10366511007, 10366511008, 10366511009, 10366511010, 10366511011, 10366511012, 10366511013, 10366511014, 10366511015, 10366511016, 10366511017, 10366511018, 10366511019, 10366511020

METHOD BLANK: 2407271 Matrix: Water
 Associated Lab Samples: 10366511001, 10366511002, 10366511003, 10366511004, 10366511005, 10366511006, 10366511007, 10366511008, 10366511009, 10366511010, 10366511011, 10366511012, 10366511013, 10366511014, 10366511015, 10366511016, 10366511017, 10366511018, 10366511019, 10366511020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/22/16 12:51	

LABORATORY CONTROL SAMPLE: 2407272

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	99.5	99	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2412656 2412657

Parameter	Units	10366511001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	33.0	100	100	129	130	96	97	70-130	0	20	

MATRIX SPIKE SAMPLE: 2412658

Parameter	Units	10366511011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.0	100	105	101		

QUALITY CONTROL DATA

Project: NYSD - BLDG.11B-2nd Floor

Pace Project No.: 10366511

QC Batch: 442170 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: ICPMS Metals, Drinking Water
 Associated Lab Samples: 10366511021, 10366511022, 10366511023, 10366511024, 10366511025, 10366511026, 10366511027, 10366511028, 10366511029, 10366511030, 10366511031

METHOD BLANK: 2409088 Matrix: Water
 Associated Lab Samples: 10366511021, 10366511022, 10366511023, 10366511024, 10366511025, 10366511026, 10366511027, 10366511028, 10366511029, 10366511030, 10366511031

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	ND	0.10	10/20/16 13:23	

LABORATORY CONTROL SAMPLE: 2409089

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	100	95.1	95	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 2409585 2409586

Parameter	Units	10366511021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.6	100	100	100	100	99	99	70-130	0	20	

MATRIX SPIKE SAMPLE: 2409587

Parameter	Units	10366511031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	11.1	100	107	96	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project:
